



EC Certificate of conformity VIGIL'Ex Vent Panel



CUSTOMER

Customer : **SPECIMEN**
Purchase Order Number : 199999-010 Qty : 22

PRODUCT SPECIFICATION

Type : **VIGIL'Ex VL** Serial number : **160123**
Size : **586x920** Date of manufacturing : **17/2015**
Material : **Stainless steel 1.4307 / EPDM** Manufactured quantity : **30**

Marking : **Ex II GD**
Burst pressure unit : **100 mbar \pm 15% @22° C**

BURST TEST RESULTS

Tests made according EN14797:2006

Serial number tested : **160123**
Quantity tested : **4**
Test result : **(1) 102 mbar* - Mini : 85/ Maxi : 115 (4) 103 mbar* - Mini : 85/ Maxi : 115**
(2) 101 mbar* - Mini : 85/ Maxi : 115 (5) mbar* - Mini : 85/ Maxi : 115
(3) 99 mbar* - Mini : 85/ Maxi : 115 (6) mbar* - Mini : 85/ Maxi : 115

*Tests realized in an ambient temperature included between 15° C and 25° C.

BUILDING MATERIALS

Component	Material	Material's certificate
- Panel :	Stainless steel 1.4307 (304L)	150203
- Gasket :	EPDM (black)	

PRODUCTION QUALITY INSURANCE INFORMATION

Notified body : **INERIS**
Address : **Parc Technologique Alata BP 2 F-60550 Verneuil-en-Halatte**
N° of notified body : **0080**
N° of quality certificate : **INERIS 08ATEXQ406**
production quality Insurance certificate according to instruction of appendix IV and VII of the 94/9/EC directive

ATEX CERTIFICATION INFORMATION

Notified body : **INERIS**
Address : **Parc Technologique Alata BP 2 F-60550 Verneuil-en-Halatte**
N° of notified body : **0080**
N° of quality certificate EC : **INERIS 15ATEX0001X**
Technical file : **BE1257001-01/15**
Harmonized norm : **EN14491 : 2012 / EN14994 :2007 / EN14797 : 2006**
European directive : **94/9/CE ATEX**

We certify that safety device covered by this data has been manufactured, inspected, tested and packaged in accordance with the purchase order requirements.
All guaranty documents of this conformity certificate are on file available for examination.

Jean-Marc FAURIE 04/05/2015
Products engineer