



EC Certificate of conformity VIGIL'Ex Vent Panel

CUSTOMER

Customer : **SPECIMEN**
Purchase Order Number : 199999-005 Qty : 22

PRODUCT SPECIFICATION

Type : **VIGIL'Ex VM** Serial number : **133998**
Size : **586x920** Date of manufacturing : **30/2011**
Material : **Stainless Steel 1.4307 / EPDM** Manufactured quantity : **30**

Marking : **Ex II GD**
Burst pressure unit : **100 mbar \pm 20% @22° C**

BURST TEST RESULTS

Tests made according EN14797:2006

Serial number tested : **133998**
Quantity tested : **4**
Test result : **(1) 102 mbar* - Mini : 80/ Maxi : 120 (4) 103 mbar* - Mini : 80/ Maxi : 120**
(2) 101 mbar* - Mini : 80/ Maxi : 120 (5) mbar* - Mini : 80/ Maxi : 120
(3) 99 mbar* - Mini : 80/ Maxi : 120 (6) mbar* - Mini : 80/ Maxi : 120

*Tests realized in an ambient temperature included between 15° C and 25° C.

BUILDING MATERIALS

Component	Material	Material's certificate
- Panel :	Stainless Steel 1.4307 (304L)	110701
- Gasket :	EPDM (black)	

PRODUCTION QUALITY INSURANCE INFORMATION

Notified company : **INERIS**
Address : **Parc Technologique Alata BP 2 F-60550 Verneuil-en-Halatte**
N° of notified company : **0080**
N° of quality certificat : **INERIS 08ATEXQ406**
production quality Insurance certificate according to instruction of appendix IV and VII of the 94/9/EC directive

ATEX CERTIFICATION INFORMATION

Notified company : **INERIS**
Address : **Parc Technologique Alata BP 2 F-60550 Verneuil-en-Halatte**
N° of notified company : **0080**
N° of quality certificat EC : **INERIS 08ATEX0038X**
Technical file : **BE1257001-01/09**
Harmonized norm : **EN14491 : 2006 / EN14994 :2007 / EN14797 : 2006**
European directive : **94/9/CE ATEX**

We certify that the Vents covered by this data have been manufactured, inspected, tested and packaged in accordance with the purchase order requirements.
All guaranty documents of this conformity certificate are on file available for examination

Fabrice GUIGNARD 30/08/2011
Quality controller